

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY

(WATER ANALYSIS REPORT)

REF. NO:- 238 SAMPLE PROVIDED BY:- Seth Hukam Chaud


S.D. Public Sr. Sec. School

REF. DT. 28/6/21 SAMPLE COLLECTED:- New Prem Nagar, Sodal Road, Jd.

SR. NO.	TEST	REQUIRED LIMIT IS10500	SAMPLE (1)	SAMPLE (2)	SAMPLE (3)	SAMPLE (4)
1	COLOUR	5 HAZEN	Colourless			
2	ODOUR	UNOBJECTIONABLE	Odourless			
3	TASTE	AGREEABLE	Tasteless			
4	PH	6.5-8.5	6.6			
5	TOTAL HARDNESS AS CaCO ₃	300 mg/l	40.0			
6	DISSOLVED SOLIDS(TDS)	500 ppm	58			
7	ALKALINITY	200 mg/l	30.0			
8	CALCIUM AS Ca ⁺⁺	75 mg/l	11.0			
9	IRON	0.3 mg/l	0.1			
10	CHLORIDE	250 mg/l	20.0			
11	SULPHATE	150 mg/l	—			
12	NITRATES	4.5 mg/l	Nd			
13	RESIDUAL CHLORINE	0.2 mg/l	Nd			
14	FLUORIDE	1.0 mg/l	Nd			
15	LEAD	0.05 mg/l	—			
	BACTERIAL TEST		/			
	TOTAL COLIFORM COUNT		/			
	BY MPN METHOD PER 100ML		Nd			
	TOTAL E-COLI COUNT		/			
	BY MPN METHOD PER 100ML		/			

REMARKS:-

The provided water sample found satisfactory as per the applied tests.



[Signature]
Analyst
Municipal Corporation
Jalandhar 30/6/21